California Department of Public Health Product WorkSheet				
Manufacturing Company Information	Product Brand:	Everpure		
Pentair Residential Filtration, LLC				
5730 N. Glen Park Road	Product Model:	BW-100 Drinking Water system		
Milwaukee, Wisconsin 53209	CDPH registration #	12-2143		
Phone: (262)-238-4400	Replacement Cartridge	BW-100		

Operating Parameters	SI Units	Metric Units	
Service Flow Rate	0.5 gpm	1.9 lpm	
System Capacity	1500 gallons	5670 L	

Website: www.pentairaqua.com

System Capacity	1500 gallons	5670 L
Pressure	10-125 psi	0.7 - 8.7 Kg/cm ²
Temperature	35-100°F	1.6-37.8°C

	Everpure BW-100 D	rinking Water system Perfor	mance Data Sheet	
Contaminat Reduction Claims	Challenge Concentration	Maximum Permissible Product Water Concentration	Reduction Requirements	Reduction Average
Cyst	Minimum 50,000/mL		≥ 99.95%	99.99%

Note: The manufacturer is required to re-test the product every 5 years for material safety, structural integrity and all performance claims made. Any change to the product must be submitted to the certification agency for a technical review. Testing may be required sooner based on the technical review.

WARNING: Do not use with water that is microbiologically unsafe or of unknown quality without adequate disinfection before or after the system. Systems certified for cyst reduction may be used on disinfected waters that may contain filterable cysts.

Note: The system must be installed and maintained according to manufacturer's recommendations, including replacement of filter cartridges. The contaminants or other substances removed or reduced by this system are not necessarily in your water. Please see Product Installation manual for details.